Report Date: 9/14/2022 Report Time: 4:02 PM EDT

Region II Hotline Log Entry Information

**Data ID:** 878010

**Date Of Report:** 11/12/2010 **NRC** #: 959674 **State** #: 185152431 **ERNS** #:

Material Type: Haz Receiver: Rothouse

Material / Amount: NATURAL GAS (0 UNKNOWN AMOUNT);

Location: Street:

City: BRONX County: BRONX State: NY Latitude: Longitude:

Source of Pollution: CON EDISON

Water Body:

State Or EPA Responded:

Initial EPA Action: Contacted NY DEP/Gilmore

Status: 2 - Closed

URL:

### Associated Action Reports

	Associated Action Reports		
ntaID: 0341981			
Date: 11/12/2010	Time: 10:46	Time: 10:46	
Duty Officer/Responder Name: Rothouse	NRC Report #: 959674	Hotline Log DataID: 878010	
Action Information			
Description: Per NYC DEP,	the NY DEC is looking into the situation.		
Follup-Up:			
Person Contacted			
Name:			
Organization:			
Phone #:			

# NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

\*\*\*GOVERNMENT USE ONLY\*\*\*GOVERNMENT USE ONLY\*\*\*

Information released to a third party shall comply with any

applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 959674

## INCIDENT DESCRIPTION

\*Report taken by: E4 NICHOLAS PROCKO at 10:27 on 12-NOV-10

Incident Type: PIPELINE

Incident Cause: OPERATOR ERROR

Affected Area:

The incident was discovered on 12-NOV-10 at 09:52 local time.

Affected Medium: AIR INTO THE AIR

### REPORTING PARTY

Name: WILLIAM WAINWRIGHT

Organization: CON EDISON

Address: 128 WEST END AVE.

NEW YORK, NY 10003

CON EDISON called for the responsible party.

PRIMARY Phone: (212)5806763

# INCIDENT LOCATION

490 HUNT POINT AVE County: BRONX

City: BRONX State: NY

## RELEASED MATERIAL(S)

CHRIS Code: ONG Official Material Name: NATURAL GAS

Also Known As:

Qty Released: 0 UNKNOWN AMOUNT

# DESCRIPTION OF INCIDENT

THE CALLER IS REPORTING THAT A FORKLIFT HIT A REGULATOR TRANSMISSION GAUGE LINE WHICH CAUSED A LEAK OF AN UNKNOWN AMOUNT OF NATURAL GAS ON THEIR PIPELINE. THE FORKLIFT WAS BEING OPERATED BY A THIRD PARTY. THE TRANSMISSION LINE WAS SHUT DOWN TO SECURE THE LEAK.

INCIDENT DETAILS

Pipeline Type: TRANSMISSION

DOT Regulated: UNKNOWN

Pipeline Above/Below Ground: ABOVE

Exposed or Under Water: NO Pipeline Covered: UNKNOWN

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN

INJURIES: NO Hospitalized: Empl/Crew: Passenger: FATALITIES: NO Empl/Crew: Passenger: Occupant:

EVACUATIONS: YES Who Evacuated: Radius/Area:

Damages:

Direction of Hours Closure Type Description of Closure Closed Closure

Air:

Major Art Road: N

Waterway: N Track:

Passengers Transferred: NO Environmental Impact: UNKNOWN

Media Interest: NONE Community Impact due to Material:

REPORTING PARTY

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: WILLIAM WAINWRIGHT

Organization: CON EDISON

Address: 128 WEST END AVE.

NEW YORK, NY 10003

PRIMARY Phone: (212)5806763

Type of Organization: PUBLIC UTILITY

REMEDIAL ACTIONS

THE LINE WAS SECURED. Release Secured: YES

Release Rate:

Estimated Release Duration:

WEATHER

Weather: UNKNOWN, <a>F</a>

ADDITIONAL AGENCIES NOTIFIED

Federal: NONE

State/Local: NY PSC, NY DEP, FD State/Local On Scene: NONE State Agency Number:

NOTIFICATIONS BY NRC

ATLANTIC STRIKE TEAM (MAIN OFFICE)

12-NOV-10 10:34 (609)7240008

USCG ICC (ICC ONI)

12-NOV-10 10:34 (301)6693363

CT DEPT OF EMERGENCY MGMT (COMMISSIONER)

12-NOV-10 10:34 (860)2560800

DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE) 12-NOV-10 10:34 (202)3661863

U.S. EPA II (MAIN OFFICE)

12-NOV-10 10:36 (732)3214370 ROTHOUSE

USCG NATIONAL COMMAND CENTER (MAIN OFFICE)

12-NOV-10 10:35 (202)3722100 CDO

NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)

12-NOV-10 10:34 (202)2829201

NJ OFC HMLND SECURITY & PREPAREDNES (COMMAND CENTER) 12-NOV-10 10:34 (609) 9636817

NJ STATE POLICE (MARINE SERVICES BUREAU)

12-NOV-10 10:34 (609)9636900

NOAA RPTS FOR NY (MAIN OFFICE)

12-NOV-10 10:34 (206) 5264911 NATIONAL RESPONSE CENTER HQ (MAIN OFFICE) 12-NOV-10 10:35 (202)2671136 NRCDO BUREAU TOXIC SUBSTANCE R. WILBURN (MAIN OFFICE) 12-NOV-10 10:34 (518) 4027810 NY STATE DEC SPILL HOTLINE (MAIN OFFICE) 12-NOV-10 10:34 (518)4577362 PIPELINE & HAZMAT SAFETY ADMIN (OFFICE OF PIPELINE SAFETY (AUTO)) 12-NOV-10 10:34 (202)3660568 SECTOR NEW YORK (COMMAND CENTER) 12-NOV-10 10:37 (718)3544353 GARCIA NJ DEP POC: DUTY OFFICER (MAIN OFFICE)

### ADDITIONAL INFORMATION

THERE IS A INCIDENT COMMAND POST SET UP FOR THIS INCIDENT.

12-NOV-10 10:34 (609)5882848
USCG DISTRICT 1 (COMMAND CENTER)
12-NOV-10 10:34 (617)2238555

\*\*\* END INCIDENT REPORT # 959674 \*\*\*
Report any problems or Fax number changes by calling 1-800-424-8802

PLEASE VISIT OUR WEB SITE AT http://www.nrc.uscg.mil